



CITY OF ELMHURST
209 NORTH YORK STREET
ELMHURST, ILLINOIS 60126-2759
(630) 530-3000
www.elmhurst.org

SCOTT M. LEVIN
MAYOR
JACKIE HADDAD-TAMER
CITY CLERK
DAN CURRAN
CITY TREASURER
JAMES A. GRABOWSKI
CITY MANAGER

ADDENDUM

2022 FLUSHING AND SAMPLING STATION MATERIAL PROJECT NO. 22-33

ADDENDUM #1 - Water Sampling Station Model # Change

Thursday, April 14, 2022

Under the Specification section:

RETURN WITH BID
PROPOSAL FOR
2022 FLUSHING AND SAMPLING STATION MATERIALS
PROJECT NO. 22-33

Materials to be furnished:

- (1) **Eclipse #88-SS Extreme Cold With 3-foot pedestal water sampling station:**
The #88 Extreme cold with 3-foot pedestal water sampling station shall be 5 foot bury, with a 3/4" FIP inlet and 7/16" unthreaded blow off and sampling bibb. Station shall be enclosed in a lockable, non-removable aluminum box with hinged openings. When open, the station shall require no key for operation, and all water flow shall pass thru an all stainless steel waterway. All working parts shall be of stainless steel and serviceable from above ground with no digging or replacement needed. A stainless steel pet cock will be located below the sampling bibb to allow pumping of any water remaining inside the station to insure non-freezing. This station shall be model #88-SS as manufactured by Kupferle Foundry, St. Louis MO. 63102
- The above change replaces the Eclipse #82 Water Sampling Station.

If you have any questions, please feel free and call me at 630-530-3036.

Thank You,
Chris Dufort
Superintendent of Utilities